

NOTES:

- THE PERMANENT CONNECTION BETWEEN THE CITY'S INSTALLATION AND THE
 DEVELOPER'S CONSTRUCTION SHALL BE MADE BY THE DEVELOPER'S CONTRACTOR.
 CONTRACTOR SHALL INSTALL VAULT AND VAULT COVER AFTER CITY FORCES
- COMPLETE THEIR WORK.
- VAULT TO BE 1.5' FROM THE CURB FACE OR AS DIRECTED BY THE ENGINEER.

DETECTOR CHECK REQUIREMENTS RELATED TO FIRE SERVICE IMPROVEMENTS GREATER THAN 2" REF. & REV. AUG. 2002

CITY OF FRESNO